

UNITED REPUBLIC OF TANZANIA
FACTORIES ORDINANCE, 1950 – SECTIONS 37

L.D. Form (F) 108.

Form prescribed by the Minister for Labour for
REPORT OF EXAMINATION OF STEAM BOILER UNDER NORMAL STEAM PRESSURE

This form may also be used (so far as applicable) for supplementary reports on Economizers and (Super-heaters)

-
1. **Name of occupier** COMPANY ABC LTD
-
2. **Address of factory or other premises where steam boiler is situated** P.O.BOX ~~xxx~~ SONGEA
-
3. **Type, description and distinctive number of boiler.** VERTICAL WATERTUBE BOILER NO, 10
-
4. **Condition.** (External) GOOD
-
5. **Fittings and attachments:-**
- (a) (i) Is the safety valve so adjusted as to prevent the boiler being worked at a pressure greater than the maximum permissible working pressure specified in the last report (L.D. Form (F) 105) on the examination when cold? YES, SET AT 47.5 BAR
- (ii) If a lever safety valve, is the weight secured on the lever in the correct position? N/A
- (b) Is the pressure gauge working correctly YES
- (c) Is the water gauge in proper working order? YES
-
6. **Repairs** (if any) required, and period within which they should be executed and any other conditions which the authorized boiler inspector thinks, it necessary to specify for securing safe working. NIL
-
7. **Other observations.** NEXT EXAMINATION: MAY 2015

I, (full name in BLOCK LETTER), RAMADHAN MSIMBIRA hereby declare that I am a boiler inspector authorized by the Chief Inspector of Factories for the purpose of Section 37 of the Factories Ordinance, 1950, by Certificate No. GEN/SB/14 dated 09/08/1989 and that, on 19/09/2014 I examined the steam boiler above described under normal steam pressure.

I certify that the above is true report of the result.

Date 19/09/ 2014

Address P.O. BOX xxx
SONGEA

Signature of approved Inspector

TO BE ATTACHED TO THE GENERAL REGISTER